

SUBMITTAL

**Part Number
2016056**

SUBMITTED TO _____
 COMPANY _____
 JOB NAME _____
 EQUIPMENT _____
 SIGNATURE _____
 DATE _____

© 2007 COX ENGINEERING DBA CAMBRIDGEPORT AIR SYSTEMS. THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO COX ENGINEERING COMPANY DBA CAMBRIDGEPORT AIR SYSTEMS. THIS DOCUMENT OR THE INFORMATION CONTAINED IN WHOLE OR IN PART MAY NOT BE ISSUED TO ANOTHER PARTY WITHOUT WRITTEN CONSENT AND AUTHORIZATION FROM CAMBRIDGEPORT.

SUBMITTAL

REVISIONS			
ZONE	REV.	DESCRIPTION	DATE

MATERIAL: 18 GA GALV. (68.1 LBS.)

Approved By: _____
Date: _____

FEATURES:

1. ONE PIECE WELDED CONSTRUCTION
2. CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL.
3. ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND.
4. GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING.
5. CURB ADAPTER IS FULLY INSULATED.
6. SUPPLY TRANSITION AND RETURN PLENUM INCLUDED.

Cambridgeport			
UNLESS OTHERWISE SPECIFIED:	CUST. ORDER NO.	DRAWN	PRG
TOLERANCES:	DATE: 11/21/19	ASS'Y, ADAPTER	
DECIMALS = + .003 FRACTIONS = + 1/16 ANGLES = + .1°	CUST. ORDER NO. YORK P.C.G.4A.30		
MATERIAL CONDITIONS:	SUBMITTAL NO.	NEW CARRIER 48VL-E30 (CP11A)	
REMOVE ALL BURRS & SHARP EDGES: ALL DIMENSIONS ARE O.D.	DETAIL OF	SHEET 1	OF 1
2016056		PART NO. 2016056	

FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.
 CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.