

## SUBMITTAL

**Part Number**  
**2016056**

SUBMITTED TO \_\_\_\_\_  
 COMPANY \_\_\_\_\_  
 JOB NAME \_\_\_\_\_  
 EQUIPMENT \_\_\_\_\_  
 SIGNATURE \_\_\_\_\_  
 DATE \_\_\_\_\_

© 2007 COX ENGINEERING DBA CAMBRIDGEPORT AIR SYSTEMS. THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO COX ENGINEERING COMPANY DBA CAMBRIDGEPORT AIR SYSTEMS. THIS DOCUMENT OR THE INFORMATION CONTAINED IN WHOLE OR IN PART MAY NOT BE ISSUED TO ANOTHER PARTY WITHOUT WRITTEN CONSENT AND AUTHORIZATION FROM CAMBRIDGEPORT.

## SUBMITTAL

REVISIONS			
ZONE	REV.	DESCRIPTION	DATE

Approved By: \_\_\_\_\_  
 Date: \_\_\_\_\_

**FEATURES:**

1. ONE PIECE WELDED CONSTRUCTION
2. CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL.
3. ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND.
4. GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING.
5. CURB ADAPTER IS FULLY INSULATED.
6. SUPPLY TRANSITION AND RETURN PLENUM INCLUDED.

<b>Cambridgeport</b>		NORTH 8 Farnham Drive Salem, MA 01962	1-800-648-2872 1-877-648-2872	SOUTH 2529 Lamar Ave Lamar, MO 64505 Memphis TN 38118
<b>HVAC Accessories &amp; Engineered Systems</b>				
UNLESS OTHERWISE SPECIFIED:	CUST. NO.	DRAWN	PRG	DESCRIPTION
TOLERANCES:	CUST. DIMS	DATE:	11/21/19	
DECIMALS = + .003	NEW YORK P.C.G.4A.30		ASS'Y, ADAPTER	
FRACTIONS = + 1/16	NEW YORK CARRIER 48VL-E30 (CP11A)		SUBMITTAL NO.	
ANGLES = + 1°	MATERIAL CONDITIONS:	REV.	PART NO.	
REMOVE ALL BURRS & SHARP EDGES:	ALL DIMENSIONS ARE O.D.	DETAIL OF	2016056	SHEET 1 OF 1
			2016056	REV.

MATERIAL: 18 GA GALV. ( 68.1 LBS. )

### FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

### CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.  
 CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.